



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS
LANSING

MARLON I. BROWN, DPA
DIRECTOR

Bureau of Fire Services - Cannabis Facilities

Code Spotlight – Processor - Staff

38.6.1.2 Staffing.

38.6.1.2.1* For other than approved, unattended processes, the extraction process shall be continuously staffed.

A.38.6.1.2.1 Nonhazardous processes might not warrant constant attendance by trained personnel.

38.6.1.2.2* Staff monitoring the extraction process shall be trained in the following:

- (1) The extraction process
- (2)* The transfer of solvents, where applicable
- (3) All emergency procedures

A.38.6.1.2.2 Staff monitoring the extraction process do not need to meet the training requirements of 38.6.1.3 of NFPA 1.

A.38.6.1.2.2(2) The transfer of solvent includes LPG liquid transfilling

38.6.1.2.3 All staff training records shall be maintained on-site and made available to the AHJ upon request.

38.6.1.3 Operator Training.

38.6.1.3.1 In addition to the provisions of 38.6.1.2, the operator of the cannabis extraction equipment shall also receive training in safe operation of the equipment.

38.6.1.3.2* Documentation of training required by 38.6.1.3.1 shall be maintained on-site and made available to the AHJ upon request.

A.38.6.1.3.2 Examples of these programs include, but are not limited to, the following:

- (1) Training programs developed by extraction equipment manufacturers
- (2) Compressed Gases in Containers, for operators of CO2 equipment
- (3) Programs by governmental organizations

*The Bureau of Fire Services (BFS) is only one Authority Having Jurisdiction (AHJ) involved with the licensing and approval for this facility. Refer to the Michigan Building Code and the Cannabis Regulatory Agency for further requirements.